



Certificate of Conformity

Certificate No.: 2088AP0513N031002
Product: Grid-Tied Solar Inverter

Brand Name: 

Test Model No.: SE 50KTL, SE 50KTL-Q3/EU-CSB, SE 50KTL-Q3/EU,
SE 50KTL-S3/EU, SE 50KTL-D3/EU, SE 60KTL,
SE 60KTL-Q3/EU-CSB, SE 60KTL-Q3/EU,
SE 60KTL-S3/EU, SE 60KTL-D3/EU

Applicant: Shenzhen Senergy Technology Co., Ltd.
Room 405, Building A, Co-talent Creative Park, No.2, LiuXianRoad, Block 68,
Xin an Street, Bao' an District, ShenZhen

Report No.: PVSP200513N031-1

Use in accordance with regulations:

The previously listed inverters are three-phases and have an automatic disconnection / connection device controlled by software, in accordance with the regulations stated below. The end user will not have access to the adjustment software.

Applied rules and standards

UNE 206006 IN:2011

Island operation detection tests of multiple photovoltaic inverters connected to a parallel network

UNE 206007-1 IN:2013

Requirements for connection to the electricity network Part 1: Inverters for connection to the distribution network

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage network



Name: James Huang
Technical Manager/ New Energy Team
Date: 2020-07-31

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.