



# Certificate of compliance

**Applicant:** Shenzhen Senergy Technology Co., Ltd  
Room 514-515, Building A, Co-talent Creative Park, No.2,  
LiuXian Road, Block 68, Xin'an Street, Bao'an District, Shenzhen  
China

**Product:** Automatic disconnection device between a generator and the  
public low-voltage grid

**Model:**

SE 1KTL-S1	SE 5KTL-D1
SE 1K5TL-S1	SE 6KTL-D1
SE 2KTL-S1	PV-3000S-V
SE 2K5TL-S1	PV-3600S-V
SE 3KTL-S1	PV-5000S-V
SE 3K6TL-S1	PVT-SE2KTL
SE 3KTL-D1	PVT-SE3KTL
SE 3K6TL-D1	PVT-SE4KTL
SE 4KTL-D1	PVT-SE5KTL
SE 4K6TL-D1	

## Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2013-08 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

## Applied rules and standards:

**DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2013-08**

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** PVDE181130N018-1  
**Certificate number:** U19-0412  
**Date of issue:** 2019-07-05

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to DIN EN ISO/IEC 17065

