



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC21024306559

Valid from: Jul.27,2021

Valid until: Nov.20,2025

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Shenzhen Senergy Technology Co., Ltd Room 405, Building A, Co-talent Creative Park, No.2, LiuXianRoad, Block 68, Xin an Street, Bao' an District, ShenZhen
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Shenzhen Senergy Technology Co., Ltd Room 405, Building A, Co-talent Creative Park, No.2, LiuXianRoad, Block 68, Xin an Street, Bao' an District, ShenZhen
NAME AND LOCATION OF THE FACTORY	APD Shenzhen DK Inc. 1-5/F, No. 1, Fengwei Street, Dakang Community, Henggang Subdistrict, Longgang District, Shenzhen P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	SOLAR(PV)Grid INVERTER See Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	NB/T32004-2018
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

APPENDIX

Page 1 of 1

CERTIFICATE NO.: CQC21024306559

PAPER:

SE 7KTL-D1

直流输入:MPPT 电压范围 70V-540Vdc, 最大直流输入电压 550Vdc, 最大输入电流 13A/13A;
交流输出:~, 220V, 50/60Hz, max. 35A, 额定交流输出功率 7kW;

SE 8KTL-D1

直流输入:MPPT 电压范围 70V-540Vdc, 最大直流输入电压 550Vdc, 最大输入电流 26A/13A;
交流输出:~, 220V, 50/60Hz, max. 40A, 额定交流输出功率 8kW;

SE 10KTL-D1

直流输入:MPPT 电压范围 70V-540Vdc, 最大直流输入电压 550Vdc, 最大输入电流 26A/13A;
交流输出:~, 220V, 50/60Hz, max. 45. 5A, 额定交流输出功率 10kW。

NOTE: This appendix is valid when used with the certificate.



CHINA QUALITY CERTIFICATION CENTRE