



Product Service

# Attestation of Conformity

No. T8A 001965 0013 Rev. 01

**Holder of Certificate:** **Shenzhen Senergy Technology Co., Ltd.**Room 405, Building A  
Co-talent Creative Park  
No.2, LiuXian Road, Block 68, Xin'an Street  
Bao'an District  
518101 Shenzhen  
PEOPLE'S REPUBLIC OF CHINA**Product:** **Converter  
(PV grid-interactive inverter)**

This Attestation of Conformity is issued on a voluntary basis in support of the Conformity Assessment Module A of Radio Equipment Directive 2014/53/EU. On the basis of the referenced test reports, the samples of the listed product were found to comply with the essential requirements of the above mentioned directive as implemented in the standards used valid at the time the tests were carried out. For the requirements of the Article(s) 3(2) and 3(3) only harmonized standards valid at the moment of issuing where used. The used standards cover the essential requirements of the Radio Equipment Directive as applicable to this product. The manufacturer must ensure compliance of the manufactured products with the technical documentation and other requirements of the Radio Equipment Directive that apply to them. National legal requirements have to be considered before bringing the product to the market. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 6877219000502**Date,** 2021-06-25

( Laurent Yuan )



Product Service

# Attestation of Conformity

No. T8A 001965 0013 Rev. 01

**Model(s):** PV-3000S-V, PV-3600S-V, PV-5000S-V,  
SE 1KTL-S1, SE 1K5TL-S1, SE 2KTL-S1,  
SE 2K5TL-S1, SE 3KTL-S1, SE 3K6TL-S1,  
SE 3KTL-D1, SE 3K6TL-D1, SE 4KTL-D1,  
SE 4K6TL-D1, SE 5KTL-D1, SE 6KTL-D1

## Parameters:

Ratings: See below table for details

Protection Class: I

Test report No.:

6877219000502 [EN 300 328, EN IEC 62311, EN 50665];  
6877219000402 [EN 301 489-1, EN 301 489-17, EN IEC 61000-6-1, EN 61000-6-3,  
EN IEC 61000-6-2, EN IEC 61000-6-4, EN 61000-3-12, EN IEC 61000-3-11];  
64290180422402 [EN 62109-1, EN 62109-2]

## Tested according to:

EN 300 328 V2.2.2:2019  
EN IEC 62311:2020  
EN 50665:2017  
EN 301 489-1 V2.2.3:2019  
EN 301 489-17 V3.2.4:2020  
EN IEC 61000-6-1:2019  
EN 61000-6-3:2007/A1:2011  
EN IEC 61000-6-2:2019  
EN IEC 61000-6-4:2019  
EN 61000-3-12:2011  
EN IEC 61000-3-11:2019  
EN 62109-1:2010  
EN 62109-2:2011

Page 2 of 4

After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives the manufacturer may sign a Declaration of Conformity and apply the CE-marking.



# Attestation of Conformity

No. T8A 001965 0013 Rev. 01

Model:	SE 1KTL-S1	SE 1K5TL-S1	SE 2KTL-S1	SE 2K5TL-S1
Maximum rated d.c. input voltage	600 Vd.c.	600Vd.c.	600 Vd.c.	600 Vd.c.
PV input MPPT operating voltage range	70 ~ 580 Vd.c.	70-580Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.
Maximum operating PV input current	13 Ad.c.	13 Ad.c.	13 Ad.c.	13 Ad.c.
Maximum total PV array s-c current	15 Ad.c.	15Ad.c.	15 Ad.c.	15 Ad.c.
a.c. output voltage range	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	4,8 Aa.c.	7,2 Aa.c	9,5 Aa.c.	11,9 Aa.c..
Nominal output active power Pn	1 kW	1.5kW	2 kW	2.5 kW
Power factor	0,8 ind. ~ 0,8 cap.	0,8 ind. ~0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.
Temperature range	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C
Degree of protection	IP 65	IP 65	IP 65	IP 65
Protection class	I	I	I	I

Model:	SE 3KTL-S1	PV-3000S-V	SE 3K6TL-S1	PV-3600S-V
Maximum rated d.c. input voltage	600 Vd.c.	600Vd.c.	600 Vd.c.	600Vd.c.
PV input MPPT operating voltage range	70 ~ 580 Vd.c.	70-580Vd.c.	70 ~ 580 Vd.c.	70-580Vd.c.
Maximum operating PV input current	13 x 2 Ad.c	13 x 2 Ad.c	13 x 2 Ad.c	13 x 2 Ad.c
Maximum total PV array s-c current	15 x 2 Ad.c.	15 x 2 Ad.c.	15 x 2 Ad.c.	15 x 2 Ad.c.
a.c. output voltage range	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	14,3 Aa.c.	14,3Aa.c.	17,2 Aa.c.	17,2Aa.c.
Nominal output active power Pn	3 kW	3kW	3.6 kW	3.6kW
Power factor	0,8 ind. ~ 0,8 cap.	0,8 ind. ~0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~0,8 cap.
Temperature range	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C
Degree of protection	IP 65	IP 65	IP 65	IP 65
Protection class	I	I	I	I



Product Service

# Attestation of Conformity

No. T8A 001965 0013 Rev. 01

Model:	SE 3KTL-D1	SE 3K6TL-D1	SE 4KTL-D1	SE 4K6TL-D1	SE 5KTL-D1	SE 6KTL-D1	PV-5000S-V
Maximum rated d.c. input voltage	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600Vd.c.
PV input MPPT operating voltage range	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70-580Vd.c.
Maximum operating PV input current	13 × 2 Ad.c.	13 × 2 Ad.c.	13 × 2 Ad.c.	13 × 2 Ad.c.	13 × 2 Ad.c.	13 × 2 Ad.c.	13 × 2 Ad.c.
Maximum total PV array s-c current	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.
a.c. output voltage range	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.	220/230Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	14,3 Aa.c.	16,7 Aa.c.	19,1 Aa.c.	21,95 Aa.c.	23,8 Aa.c.	28,6 Aa.c.	23,8 Aa.c.
Nominal output active power P <sub>n</sub>	3 kW	3.68 kW	4.0 kW	4.6 kW	5.0 kW	6.0 kW	5.0kW
Power factor	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.	0,8 ind. ~ 0,8 cap.
Temperature range	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C	-25~+60°C
Degree of protection	IP 65	IP 65	IP 65	IP 65	IP 65	IP 65	IP 65
Protection class	I	I	I	I	I	I	I

Page 4 of 4

After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives the manufacturer may sign a Declaration of Conformity and apply the CE-marking.