

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Converter (PV grid-interactive inverter)
Name and address of the applicant	Shenzhen Senergy Technology Co., Ltd. Room 405, Building A Co-talent Creative Park No.2, LiuXian Road, Block 68, Xin'an Street Bao'an District 518101 Shenzhen PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Shenzhen Senergy Technology Co., Ltd. Room 405, Building A, Co-talent Creative Park, No.2, LiuXian Road, Block 68, Xin'an Street, Bao'an District, 518101 Shenzhen, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	APD Shenzhen DK Inc. 1-5/F, No.1, Fengwei Street, Dakang Community, Henggang Subdistrict, Longgang District, 518115 Shenzhen, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	See below pages
Model/type Ref.	SE 17KTL-D3, SE 20KTL-D3, SE 22KTL-D3, SE 25KTL-D3, SE 28KTL-D3, SE 30KTL-D3 VP 17KTL-D3, VP 20KTL-D3, VP 22KTL-D3, VP 25KTL-D3, VP 28KTL-D3, VP 30KTL-D3 SE 17KTL-D3/EU, SE 20KTL-D3/EU, SE 22KTL-D3/EU, SE 25KTL-D3/EU, SE 28KTL-D3/EU, SE 30KTL-D3/EU, SE 30KTL-D3/EU-CSB
A sample of the product was tested and found to be in conformity with	IEC 62109-1:2010 IEC 62109-2:2011
as shown in the Test Report Ref. No. which forms part of this certificate	085-203102201-000

Page 1 of 4

This CB Test Certificate is issued by the National Certification Body

CBS 001965 0017 Rev. 00

Date, 2021-01-08



(Billy Qiu)



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trade mark (Image)



Ratings and principal characteristics (continued)

Model:	SE 17KTL-D3	SE 20KTL-D3	SE 22KTL-D3	SE 25KTL-D3	SE 28KTL-D3	SE 30KTL-D3
Maximum rated d.c. input voltage	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.
PV input operating voltage range	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.
Maximum operating PV input current	25 × 2 Ad.c.	25 × 2 Ad.c.	25 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.
Maximum total PV array s-c current	30 × 2 Ad.c.	30 × 2 Ad.c.	30 × 2 Ad.c.	42 × 2 Ad.c.	42 × 2 Ad.c.	42 × 2 Ad.c.
a.c. output voltage	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	28,3 Aa.c.	33,5 Aa.c.	35 Aa.c.	40 Aa.c.	45 Aa.c.	48 Aa.c.
Nominal output active power P _n	17 kW	20 kW	22 kW	25 kW	28 kW	30 kW
Power factor	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.
Protection class	I	I	I	I	I	I

Page 2 of 4

This CB Test Certificate is issued by the National Certification Body

CBS 001965 0017 Rev. 00

Date, 2021-01-08



(Billy Qiu)



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Model:	VP 17KTL-D3	VP 20KTL-D3	VP 22KTL-D3	VP 25KTL-D3	VP 28KTL-D3	VP 30KTL-D3
Maximum rated d.c. input voltage	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.
PV input operating voltage range	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.
Maximum operating PV input current	25 × 2 Ad.c.	25 × 2 Ad.c.	25 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.
Maximum total PV array s-c current	30 × 2 Ad.c.	30 × 2 Ad.c.	30 × 2 Ad.c.	42 × 2 Ad.c.	42 × 2 Ad.c.	42 × 2 Ad.c.
a.c. output voltage	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	28,3 Aa.c.	33,5 Aa.c.	35 Aa.c.	40 Aa.c.	45 Aa.c.	48 Aa.c.
Nominal output active power P _n	17 kW	20 kW	22 kW	25 kW	28 kW	30 kW
Power factor	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.
Protection class	I	I	I	I	I	I

Page 3 of 4

This CB Test Certificate is issued by the National Certification Body

CBS 001965 0017 Rev. 00

Date, 2021-01-08



(Billy Qiu)



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Model:	SE 17KTL-D3/EU	SE 20KTL-D3/EU	SE 22KTL-D3/EU	SE 25KTL-D3/EU	SE 28KTL-D3/EU	SE 30KTL-D3/EU, SE 30KTL-D3/EU-CSB
Maximum rated d.c. input voltage	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.	1000 Vd.c.
PV input operating voltage range	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.	180 - 1000 Vd.c.
Maximum operating PV input current	25 × 2 Ad.c.	25 × 2 Ad.c.	25 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.	37,5 × 2 Ad.c.
Maximum total PV array s-c current	30 × 2 Ad.c.	30 × 2 Ad.c.	30 × 2 Ad.c.	45 × 2 Ad.c.	45 × 2 Ad.c.	45 × 2 Ad.c.
a.c. output voltage	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.	3N/PE~ 230/400 Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	28,3 Aa.c.	33,5 Aa.c.	35 Aa.c.	40 Aa.c.	45 Aa.c.	48 Aa.c.
Nominal output active power P _n	17 kW	20 kW	22 kW	25 kW	28 kW	30 kW
Power factor	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.	0,8 ind. - 0,8 cap.
Protection class	I	I	I	I	I	I



(Billy Qiu)

