



Attestation of Conformity

Attestation No.: 1988AP1125N025001
Equipment: SOLAR (PV) Grid INVERTER
Brand Name: Senergy
Test Model No.: SE 50KTL, SE 60KTL
Applicant: Shenzhen Senergy Technology Co., Ltd
Room 405, Building A, Co-talent Creative Park, No.2, LiuXianRoad, Block 68,
Xin an Street, Bao' an District, ShenZhen
Report No.: PV180205N020-R1, PV180205N020-1, PV180205N020-2-R1,
PV180205N020-3, WT186000577

Use in accordance with regulations:

The inverters are tested for functional safety, grid protection, specified environmental influences and efficiency. For detailed information, please watch the corresponding test reports.

Applied rules and standards

IEC 60068-2-1:2007	Environmental testing – Part 2-1: Tests – Test A: Cold
IEC 60068-2-2:2007	Environmental testing – Part 2-2: Tests – Test B: Dry heat
IEC 60068-2-14:2009	Environmental testing – Part 2-14: Tests – Test N: Change of temperature
IEC 60068-2-30:2005	Environmental testing – Part 2-30: Tests – Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)
IEC 61683:1999	Photovoltaic systems – Power conditioners – Procedure for measuring efficiency
IEC 61727:2004	Characteristics of the utility interface
IEC 62116:2014	Islanding prevention measures for utility-interconnected photovoltaic inverters
EN 50530:2010	Overall efficiency of grid connected photovoltaic inverters

Name: James Huang
Technical Manager/ New Energy Team
Date: 2019-12-31

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.