

# Compliance Document

No. D 001965 0016 Rev. 00

**Holder of Certificate:** **Shenzhen Senergy Technology Co., Ltd.**

Room 405, Building A  
Co-talent Creative Park  
No.2, LiuXian Road, Block 68, Xin'an Street  
Bao'an District  
518101 Shenzhen  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Converter  
(PV grid-interactive inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290203084801

**Date,** 2021-01-04



( Billy Qiu )

# Compliance Document

No. D 001965 0016 Rev. 00

**Model(s):** SE 1KTL-S1, SE 1K5TL-S1, SE 2KTL-S1, SE 2K5TL-S1, SE 3KTL-S1, SE 3K6TL-S1, SE 3KTL-D1, SE 3K6TL-D1, SE 4KTL-D1, SE 4K6TL-D1, SE 5KTL-D1, SE 6KTL-D1

## Parameters:

Model:	SE 1KTL-S1	SE 1K5TL-S1	SE 2KTL-S1	SE 2K5TL-S1	SE 3KTL-S1	SE 3K6TL-S1
Maximum rated d.c. input voltage	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.
PV input MPPT operating voltage range	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.
Maximum operating PV input current	12.5 Ad.c.	12.5 Ad.c.	12.5 Ad.c.	12.5 Ad.c.	12.5 Ad.c.	11 Ad.c.
Maximum total PV array s-c current	15 Ad.c.	15 Ad.c.	15 Ad.c.	15 Ad.c.	15 Ad.c.	15 Ad.c.
a.c. output voltage range	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	4.8 Aa.c.	7.2 Aa.c.	9.5 Aa.c.	11.9 Aa.c.	14.3 Aa.c.	17.2 Aa.c.
Nominal output active power $P_n$	1 kW	1.5 kW	2 kW	2.5 kW	3 kW	3.6 kW
Power factor	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.

Model:	SE 3KTL-D1	SE 3K6TL-D1	SE 4KTL-D1	SE 4K6TL-D1	SE 5KTL-D1	SE 6KTL-D1
Maximum rated d.c. input voltage	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.	600 Vd.c.
PV input MPPT operating voltage range	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.	70 ~ 580 Vd.c.
Maximum operating PV input current	11 × 2 Ad.c.	11 × 2 Ad.c.	11 × 2 Ad.c.	11 × 2 Ad.c.	11 × 2 Ad.c.	11 × 2 Ad.c.
Maximum total PV array s-c current	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.	15 × 2 Ad.c.
a.c. output voltage range	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.	230 Va.c.
Nominal a.c. output frequency	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz
Maximum continuous a.c. output current	14.3 Aa.c.	16.7 Aa.c.	19.1 Aa.c.	21.95 Aa.c.	23.8 Aa.c.	28,6 Aa.c.
Nominal output active power $P_n$	3 kW	3.68 kW	4.0 kW	4.6 kW	5.0 kW	6.0 kW
Power factor	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0.8 ind. ~ 0.8 cap.	0,8 ind. ~ 0,8 cap.

**Tested according to:**

UNE 206007-1 IN:2013  
UNE 206006 IN:2011