

Compliance Document

No. D 001965 0023 Rev. 00

Holder of Certificate: **Shenzhen Senergy Technology Co., Ltd.**

Room 405, Building A
Co-talent Creative Park
No.2, LiuXian Road, Block 68, Xin'an Street
Bao'an District
518101 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Grid-Tied Solar Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203091501

Date, 2021-04-09



(Billy Qiu)

Compliance Document

No. D 001965 0023 Rev. 00

Model(s): SE 2KTL-S1/G2, SE 3KTL-S1/G2,
SE 3.6KTL-S1/G2, SE 4KTL-D1/G2,
SE 5KTL-D1/G2, SE 6KTL-D1/G2

Parameters:

Model	SE 2KTL-S1/G2	SE 3KTL-S1/G2	SE 3.6KTL-S1/G2	SE 4KTL-D1/G2	SE 5KTL-D1/G2	SE 6KTL-D1/G2
PV terminal						
Vmax. PV	500Vd.c.			550Vd.c.		
MPPT Voltage Range	50-490Vd.c.			70-540Vd.c.		
MPPT Tracker number	1			2		
Max. continuous PV input current per tracker	13Ad.c.			13/13Ad.c.		
Isc PV per tracker	15Ad.c.			15/15Ad.c.		
Grid terminal						
Rated voltage	220/230/240 Va.c.					
Rated frequency	50/60 Hz					
Maximum continuous output current	10.0Aa.c.	15.0Aa.c.	16.0Aa.c.	20.0Aa.c.	25.0Aa.c.	27.3Aa.c.
Rated output power	2000W	3000W	3600W	4000W	5000W	6000W
Maximum continuous output Apparent power	2200VA	3300VA	3600VA	4400VA	5500VA	6000VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging					

Tested according to: IEC 61727:2004
IEC 62116:2014