

Compliance Document

No. D 087538 0028 Rev. 00

Holder of Certificate: **Shenzhen Senergy Technology Co., Ltd.**
Block D, BC Park, No.18, Xiusha Rd.
Shatian Kengzi Sub-district
Pingshan District
518112 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Hybrid Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290233012801

Date, 2023-12-12



(Billy Qiu)

Compliance Document

No. D 087538 0028 Rev. 00

Model(s): SE 5KHB-D3, SE 6KHB-D3, SE 8KHB-D3, SE 10KHB-D3

Parameters:

Model	SE 5KHB-D3	SE 6KHB-D3	SE 8KHB-D3	SE 10KHB-D3
PV terminal parameters				
Maximum PV Voltage	1000 Vd.c.			
MPPT Voltage Range	160 - 950 Vd.c.			
MPPT Voltage Range (full load)	330 - 800 Vd.c.		370 - 800 Vd.c.	
Maximum continuous PV input current	15 Ad.c. / 15 Ad.c.		20 Ad.c. / 30 Ad.c.	
Isc PV	20 Ad.c. / 20 Ad.c.		30 Ad.c. / 40 Ad.c.	
Maximum continuous PV input power	9000 W		15000 W	
Battery terminal parameters				
Battery type	Lithium-ion / Lead-acid			
Voltage range	150 - 600 Vd.c.			
Rated voltage	504 Vd.c.			
Maximum charge / discharge current	25.0 Ad.c. / 25.0 Ad.c.		50.0 Ad.c. / 50.0 Ad.c.	
Maximum charge / discharge power	9000 W / 5800 W	9000 W / 7000 W	15000 W / 9100 W	15000 W / 11300 W
Maximum charge power from grid to battery	5500 W	6600 W	8800 W	11000 W
Grid terminal parameters				
Rated voltage	230/400 Va.c., 3W+N+PE			
Rated frequency	50 Hz			
Rated current output to Grid	7.2 Aa.c.	8.7 Aa.c.	11.6 Aa.c.	14.5 Aa.c.
Maximum continuous current output to Grid	8.0 Aa.c.	9.6 Aa.c.	12.7 Aa.c.	16.0 Aa.c.
Rated active power output to Grid	5000 W	6000 W	8000 W	10000 W
Maximum apparent power output to Grid	5500 VA	6600 VA	8800 VA	11000 VA
Maximum continuous current from Grid to battery	8.0 Aa.c.	9.6 Aa.c.	12.7 Aa.c.	16.0 Aa.c.
Maximum continuous current from Grid	25.0 Aa.c.			
Maximum apparent power from Grid to battery	5500 VA	6600 VA	8800 VA	11000 VA
Maximum apparent power from Grid	15800 VA			
Power factor (Cos phi), adjustable	0.8 inductive(under-excited) to 0.8 capacitive(over-excited)			



Compliance Document

No. D 087538 0028 Rev. 00

**Tested
according to:**

C10/11:2021