



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Holder of Attestation: **Shenzhen Senergy Technology Co., Ltd.**

Block D, BC Park, No.18, Xiusha Rd.
Shatian Kengzi Sub-district
Pingshan District
518122 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Grid-Tied Solar Inverter)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203091106

Date, 2024-08-30

(Billy Qiu)

Page 1 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model(s):

**SE 1.5KTL-S1/G2P, SE 2KTL-S1/G2P,
SE 3KTL-S1/G2P, SE 3.6KTL-S1/G2P,
SE 3.68KTL-D1/G2P, SE 4KTL-D1/G2P,
SE 4.6KTL-D1/G2P, SE 5KTL-D1/G2P,
SE 6KTL-D1/G2P
VP 2KTL-S1/G2P, VP 3KTL-S1/G2P,
VP 3.6KTL-S1/G2P
SE 3.68KTL-D1/G2R, SE 4KTL-D1/G2R,
SE 4.6KTL-D1/G2R,
SE 5KTL-D1/G2R, SE 6KTL-D1/G2R,
SE 1.5KTL-S1/G2R, SE 2KTL-S1/G2R,
SE 3KTL-S1/G2R, SE 3.6KTL-S1/G2R,
SE 4KTL-S1/G2R, SE 4.6KTL-S1/G2R,
SE 5KTL-S1/G2R, SE 5.5KTL-S1/G2R,
SE 6KTL-S1/G2R
VP 2KTL-S1/G2R, VP 3KTL-S1/G2R,
VP 3.6KTL-S1/G2R
SE 6KTL-D1/G2**

Page 2 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Parameters:

Model	SE 1.5KTL- S1/G2P	SE 2KTL- S1/G2P	SE 3KTL- S1/G2P	SE 3.6KTL- S1/G2P	SE 3.68KTL- D1/G2P	SE 4KTL- D1/G2P	SE 4.6KTL- D1/G2P	SE 5KTL- D1/G2P	SE 6KTL- D1/G2P
PV terminal									
Vmax. PV	500Vd.c.				550Vd.c.				
MPPT Voltage Range	50-490Vd.c.				70-540Vd.c.				
MPPT Voltage Range (full load)	100 ~ 430 Vd.c.	140 ~ 430 Vd.c.	210 ~ 430 Vd.c.	250 ~ 430 Vd.c.	120 ~ 480 Vd.c.	140 ~ 480 Vd.c.	160 ~ 480 Vd.c.	170 ~ 480 Vd.c.	210 ~ 480 Vd.c.
MPPT Tracker number	1				2				
Max. continuous PV input current per tracker	15Ad.c.				15/15Ad.c.				
Isc PV per tracker	20Ad.c.				20/20Ad.c.				
Grid terminal									
Rated voltage	220/230/240 Va.c.								
Rated frequency	50/60 Hz								
Maximum continuous output current	7.5 Aa.c.	10 Aa.c.	15 Aa.c.	16 Aa.c.	18.4 Aa.c.	20 Aa.c.	23 Aa.c.	25 Aa.c.	27.3 Aa.c.
Rated output current	6.8/6.5 /6.3 Aa.c.	9.1/8.7 /8.3 Aa.c.	13.6/13.0 /12.5 Aa.c.	16/15.7 /15.0 Aa.c.	16.7/16 /15.3 Aa.c.	18.2/17.4 /16.7 Aa.c.	20.9/ 20.0 /19.2 Aa.c.	22.7 /21.7 /20.8 Aa.c.	27.3 /26.1 /25.0 Aa.c.
Maximum output current	7.5/7.2 /6.9 Aa.c.	10.0/9.6 /9.2 Aa.c.	15.0/14.3 /13.8 Aa.c.	16/15.7 /15.0 Aa.c.	18.4/17.6 /16.9 Aa.c.	20.0/19.1 /18.3 Aa.c.	23.0 /22.0 /21.0 Aa.c.	25.0 /23.9 /22.9 Aa.c.	27.3/ 26.1 /25.0 Aa.c.
Rated output power	1500W	2000W	3000W	3600W	3680W	4000W	4600W	5000W	6000W
Rated output Apparent power	1500VA	2000VA	3000VA	3600VA	3680VA	4000VA	4600VA	5000VA	6000VA
Maximum continuous output Apparent power	1650VA	2200VA	3300VA	3600VA	4048VA	4400VA	5060VA	5500VA	6000VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging								
Enclosure	IP65								

Page 3 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Temperature Range	-25°C ~ +60°C (derating at 45°C)
Protective Class	I
Altitude	up to 4000 m

Model	VP 2KTL-S1/G2P	VP 3KTL-S1/G2P	VP 3.6KTL-S1/G2P
PV terminal			
Vmax. PV	500Vd.c.		
MPPT Voltage Range	50-490Vd.c.		
MPPT Voltage Range (full load)	140 ~ 430Vd.c.	210 ~ 430Vd.c.	250 ~ 430Vd.c.
MPPT Tracker number	1		
Max. continuous PV input current per tracker	15Ad.c.		
Isc PV per tracker	20Ad.c.		
Grid terminal			
Rated voltage	220/230/240 Va.c.		
Rated frequency	50/60 Hz		
Maximum continuous output current	10Aa.c.	15Aa.c.	16Aa.c.
Rated output current	9.1/8.7/8.3 Aa.c.	13.6/13.0/12.5 Aa.c.	16/15.7/15.0 Aa.c.
Maximum output current	10.0/9.6/9.2 Aa.c.	15.0/14.3/13.8 Aa.c.	16/15.7/15.0 Aa.c.
Rated output power	2000W	3000W	3600W
Rated output Apparent power	2000VA	3000VA	3600VA
Maximum continuous output Apparent power	2200VA	3300VA	3600VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging		
Enclosure	IP65		
Temperature Range	-25°C ~ +60°C (derating at 45°C)		
Protective Class	I		
Altitude	up to 4000 m		

Page 4 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model	SE 3.68KTL-D1/G2R	SE 4KTL-D1/G2R	SE 4.6KTL-D1/G2R	SE 5KTL-D1/G2R	SE 6KTL-D1/G2R
PV terminal					
Vmax. PV	600Vd.c.				
MPPT Voltage Range	70-550Vd.c.				
MPPT Voltage Range (full load)	100-500 Vd.c.	110-500 Vd.c.	120-500 Vd.c.	130-500 Vd.c.	160-500 Vd.c.
MPPT Tracker number	2				
Max. continuous PV input current per tracker	20/20Ad.c.				
Isc PV per tracker	30/30Ad.c.				
Grid terminal					
Rated voltage	220/230/240 Va.c.				
Rated frequency	50/60 Hz				
Maximum continuous output current	18.4 Aa.c.	20.0 Aa.c.	23.0 Aa.c.	25.0 Aa.c.	27.3 Aa.c.
Rated output current	16.7/16.0/15.3 Aa.c.	18.2/17.4/16.7 Aa.c.	20.9/20.0/19.2 Aa.c.	22.7/21.7/20.8 Aa.c.	27.3/26.1/25.0 Aa.c.
Maximum output current	18.4Aa.c.	20.0Aa.c.	23.0Aa.c.	25.0Aa.c.	27.3Aa.c.
Rated output power	3680W	4000W	4600W	5000W	6000W
Rated output Apparent power	3680VA	4000VA	4600VA	5000VA	6000VA
Maximum continuous output Apparent power	4048VA	4400VA	5060VA	5500VA	6000VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging				
Enclosure	IP65				
Temperature Range	-25°C ~ +60°C (derating at 45°C)				
Protective Class	I				
Altitude	up to 4000 m				

Page 5 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model	SE 1.5KTL-S1/G2R	SE 2KTL-S1/G2R	SE 3KTL-S1/G2R	SE 3.6KTL-S1/G2R
PV terminal				
Vmax. PV	500Vd.c.			
MPPT Voltage Range	50-490Vd.c.			
MPPT Voltage Range (full load)	80-430 Vd.c.	110-430 Vd.c.	160-430 Vd.c.	190-430 Vd.c.
MPPT Tracker number	1			
Max. continuous PV input current per tracker	20 Ad.c.			
Isc PV per tracker	30 Ad.c.			
Grid terminal				
Rated voltage	220/230/240 Va.c.			
Rated frequency	50/60 Hz			
Maximum continuous output current	7.5 Aa.c.	10.0 Aa.c	15.0 Aa.c	16.0 Aa.c
Rated output current	6.8/6.5/6.3 A.a.c	9.1/8.7/8.3 A.a.c	13.6/13.0/12.5 A.a.c	16.4 /15.7/15.0 A.a.c
Maximum output current	7.5 Aa.c.	10.0 Aa.c.	15.0 Aa.c.	16.0 Aa.c.
Rated output power	1500W	2000W	3000W	3600W
Rated output Apparent power	1500VA	2000VA	3000VA	3600VA
Maximum continuous output Apparent power	1650VA	2200VA	3300VA	3600VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging			
Enclosure	IP65			
Temperature Range	-25°C ~ +60°C (derating at 45°C)			
Protective Class	I			
Altitude	up to 4000 m			

Page 6 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model	SE 4KTL-S1/G2R	SE 4.6KTL-S1/G2R	SE 5KTL-S1/G2R	SE 5.5KTL-S1/G2R	SE 6KTL-S1/G2R
PV terminal					
Vmax. PV	600Vd.c.				
MPPT Voltage Range	70-550Vd.c.				
MPPT Voltage Range (full load)	210-500 Vd.c.	240-500 Vd.c.	260-500 Vd.c.	290-500 Vd.c.	320-500 Vd.c.
MPPT Tracker number	1				
Max. continuous PV input current per tracker	20/20Ad.c.				
Isc PV per tracker	30/30Ad.c.				
Grid terminal					
Rated voltage	220/230/240 Va.c.				
Rated frequency	50/60 Hz				
Maximum continuous output current	20.0 Aa.c.	23.0 Aa.c.	25.0 Aa.c.	27.3 Aa.c.	27.3 Aa.c.
Rated output current	18.2/17.4/16.7 A.a.c	20.9/20.0/19.2 A.a.c	22.7/21.7/20.8 A.a.c	25.0/23.9/22.9 A.a.c	27.3/26.1 /25.0 A.a.c
Maximum output current	20.0 Aa.c.	23.0 Aa.c.	25.0 Aa.c.	27.3 Aa.	27.3Aa.c.
Rated output power	4000W	4600W	5000W	5500W	6000W
Rated output Apparent power	4000VA	4600VA	5000VA	5500VA	6000VA
Maximum continuous output Apparent power	4400VA	5060VA	5500VA	6000VA	6000VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging				
Enclosure	IP65				
Temperature Range	-25°C ~ +60°C (derating at 45°C)				
Protective Class	I				
Altitude	up to 4000 m				

Page 7 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model	VP 2KTL-S1/G2R	VP 3KTL-S1/G2R	VP 3.6KTL-S1/G2R
PV terminal			
Vmax. PV	500 Vd.c.		
MPPT Voltage Range	50-490 Vd.c.		
MPPT Voltage Range (full load)	110-430 Vd.c.	160-430 Vd.c.	190-430 Vd.c.
MPPT Tracker number	1		
Max. continuous PV input current per tracker	20 Ad.c.		
Isc PV per tracker	30 Ad.c.		
Grid terminal			
Rated voltage	220/230/240 Va.c.		
Rated frequency	50/60 Hz		
Maximum continuous output current	10Aa.c.	15Aa.c.	16Aa.c.
Rated output current	9.1/8.7/8.3 A.a.c	13.6/13.0/12.5 A.a.c	16.4/15.7/15.0 A.a.c
Maximum output current	10.0/9.6/9.2 Aa.c.	15.0/14.3/13.8 Aa.c.	16/15.7/15.0 Aa.c.
Rated output power	2000W	3000W	3600W
Rated output Apparent power	2000VA	3000VA	3600VA
Maximum continuous output Apparent power	2200VA	3300VA	3600VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging		
Enclosure	IP65		
Temperature Range	-25°C ~ +60°C (derating at 45°C)		
Protective Class	I		
Altitude	up to 4000 m		

Page 8 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 087538 0022 Rev. 02

Model	SE 6KTL-D1/G2
PV terminal	
Vmax. PV	550Vd.c.
MPPT Voltage Range	70-540Vd.c.
MPPT Voltage Range (full load)	280 ~ 480Vd.c.
MPPT Tracker number	2
Max. continuous PV input current per tracker	13/13Ad.c.
Isc PV per tracker	15/15Ad.c.
Grid terminal	
Rated voltage	220/230/240 Va.c.
Rated frequency	50/60 Hz
Maximum continuous output current	27.3Aa.c.
Rated output current	27.3/26.1/25.0 Aa.c.
Maximum output current	27.3/26.1/25.0 Aa.c.
Rated output power	6000W
Rated output Apparent power	6000VA
Maximum continuous output Apparent power	6000VA
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging
Enclosure	IP65
Temperature Range	-25°C ~ +60°C (derating at 45°C)
Protective Class	I
Altitude	up to 4000 m

Tested according to:

EN 62109-1:2010
EN 62109-2:2011

Page 9 of 9

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.